


EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: HQ NADRA Islamabad
2. Method of Procurement: Single Stage Two Envelope Method
3. Title of Procurement: Supply and Installation of 135KVA Generator
4. Tender Inquiry No.: NADRA-HQ-RFB-165/2024
5. PPRA Ref. No. (TSE): TS549883E
6. Date & Time of Bid Closing: 18 November, 2024 At 1100 Hrs
7. Date & Time of Bid Opening: 18 November, 2024 At 1130 Hrs
8. No of Bids Received: 04 x Bids
9. Criteria for Bid Evaluation: As per RFP
10. Details of Bid(s) Evaluation: As under:-

Sr#	Item Description	Name of Bidder	Mark		Evaluated Cost	Rule/Regulation/SBD*/Policy/ Basis for Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
			Technical (if applicable)	Financial (if applicable)		
a	Supply and Installation of 135KVA Generators	M/s Power Vision	Qualified	Only Technical Qualification was required	7,364,280/-	Bids of 4x Firms i-e M/s Power Vision systems, M/s Multiline Enterprises, M/s MIA Energy (Pvt) Ltd. and M/s HK Global were received. Bids were opened on 18 th November, 2024. Bid of M/s MIA Energy (Pvt) Ltd. was non-responsive due to letter of bid not attached. As per technical evaluation bid of M/s Multiline Enterprises as disqualified whereas M/s Power Vision and M/s HK Global were qualified. Technical Evaluation report is attached Annex 'A'. Financial bids of technically qualified firms were opened on 19 th December, 2024. As per financial evaluation, bid of M/s Power Vision systems was the most advantageous.
		M/s HK Global	Qualified	Only Technical Qualification was required	11,399,950/-	
		M/s Multiline Enterprises	Disqualified	NA	NA	
		M/s MIA Energy Pvt Ltd.	Non Responsive	NA	NA	

Most Advantageous Bidder: **M/s Power Vision System**

11. Any other additional / supporting information, the procuring agency may like to share. N/A


Director
NADRA HQ Procurement
(Alia Abdul Razzaq)
10-Jan, 2025

2nad ra 14/25. p21

Compliance and Technical Criteria

Subject: Technical Evaluation for Supply and Installation of 135 KVA Generator (Tender # NADRA-HQ-RFB-165/2024)

Sr#	Evaluation Description	M/s Multiline Enterprises	M/s Power Vision System Pvt Ltd.	M/s HK Global Pvt Ltd
1	Evaluation of Eligibility Criteria (Annex-E)	Not qualify in Eligibility Criteria	Comply	Comply
2	Evaluation of Compliance Sheet (Annex-C)		Comply	Comply
3	Evaluation result of Evaluation Criteria (Annex-T) (Max Marks: 75 Passing Marks:50)		Obtained Marks: 70	Obtained Marks: 60
Combined Result of Evaluation		Not Qualified	Qualified	Qualified

President:

Mr. Abdul Rasheed, Director (C&IT)

Sig:

Members:

Mr. Nauman Ali, Electrical Engineer (C&IT):

Sig:

Mr. Rasheed Ahmad, AD Admin:

Sig:

Mr. Zahid Ur Rehman Shams,(Operation Division- CRMS):

Sig:

Eligibility Criteria

Subject: Technical Evaluation for Supply and Installation of 135 KVA Generator (Tender # NADRA-HQ-RFB-165/2024)

Description		Firms		
S.NO	Requirement	M/S Multiline Enterprises	M/S HK Global Pvt. Ltd	M/S Power Vision System Pvt. Ltd
1	Firm has a Valid NTN Registration (Attach document Proof as Annex "C")	yes	yes	yes
2	Firm has a Valid GST Registration (Attach document Proof as Annex "D")	yes	yes	yes
3	Firm is active on ATL list of FBR (Attach document Proof as Annex "E")	yes	yes	yes
4	Affidavit for Non-Blacklisting (Attach document Proof as Annex "F")	yes	yes	yes
5	I abide by all the terms and conditions as mentioned in the Tender documents. I also comply with BOQ, Scope of Work, evaluation criteria, Compliance Sheet and technical specification and as stated in this document Provide confirmation letter on company	yes	yes	yes
6	Firm has supplied and installed Generator sets having capacity of 100kva or above in Data Center Facility or IT Infrastructure. (Attach document Proof (POs) as Annex "H")	NO	yes	yes
	Remarks	Not Qualified	Qualified	Qualified






Compliance Sheet

Subject: Technical Evaluation for Supply and Installation of 135 KVA Generator (Tender # NADRA-HQ-RFB-165/2024)

Sr. #	Description	Comply /Not Comply		
		M/S Multiline Enterprises	M/S Power Vision System Pvt. Ltd	M/S HK Global Pvt. Ltd
1	Diesel Generator 135 kVA 50 Hz 1500 rpm 400 V			
	Output Ratings: Generator Rating 135KVA Prime Make/Assembler: International renowned brands or equivalent (duly foreign assembled / coupled due to critical Data center operation) Alternator: OEM coupled alternator OEM Controller including all other standard accessories With respect to synchronous alternators designed to comply with the following standard: Declaration of conformity ENA EREC G99 Or equivalent ENA EREC G5 Or equivalent Technical Data: Circuit Breaker Type: 3 Pole MCCB/ ACB Temperature 50°C Insulation Class: H Protection Class: IP 21 Excitation System: Self Excited Brushless Starting System of Engine: SLI/Sealed Battery & Charging System Frequency: 50 Hz Engine Speed: 1500 RPM Built-in Fuel Tank Capacity: Should have 08-Hours continuous running Engine: 6-cylinder turbo charged;water cooled Cooling system: Water-cooled. Tropical Radiator with water level switch or indicator Governor Type: Electronic. Frequency: 50Hertz. Battery and starting system: 12 ~24V DC. • Circuit Breaker Type: MCCB/ACB, 3/4 Pole. Ambient Temperature >= 50 Degree Alternator: Single bearing synchronous type. Warranty Period The Warranty Period will be for One Year Or 1000 Running Hours whichever come first the warranty period includes Preventive and Corrective maintenance with parts and consumables.	N/A Not qualify in Eligibility Criteria	Comply Reference attached	Comply Reference attached

2/4
03/12/24

[Signature]

[Signature]

13
[Signature]

Evaluation Criteria

Subject: Technical Evaluation for Supply and Installation of 135 KVA Generator (Tender # NADRA-HQ-RFB-165/2024)

Sr#	Parameter	Name of Firms		
		M/S Multiline Enterprises	M/S Power Vision System Pvt. Ltd	M/S HK Global Pvt. Ltd
1	Firm was established and registered with SECP for how many years.	N/A Not qualify in Eligibility Criteria	15	10
	(Attach document Proof as Annex "F")			
	More than 5 years = 15 Marks			
	2 to 5 years = 10 Marks			
2	Less than 2 years = Not Qualified for Evaluation		15	10
	How good are their references regarding their experience with GOP, Defense and General client with their specific SLA and relevant project experience			
	(Attach document Proof as Annex "G")			
	If all Three = 15 Marks			
3	If any Two = 10 Marks		15	15
	If anyone = 05 Marks			
	If none = Not Qualified			
	Number of Technically Qualified nationwide HR related to Gensets and Allied services.			
4	(Attach document Proof as Annex "H")		10	10
	Greater than or equal to 20 = 15			
	Less than 15 but greater than or equal to 20 = 10			
	Less than 15 but greater than or equal to 08 = 5			
5	Not qualified if HR count is less than 08		15	15
	How many number of Gensets have been supplied through work order having minimum capacity of 100 KVA, in last three (03) years' time period (2021-2024) including present period.			
	(Attach document Proof as Annex "I")			
	Minimum 100 KVA capacity Gensets will be considered.			
6	More than 15 Gensets = 15 Marks		15	15
	More than 10 Gensets but less than 15 = 10 Marks			
	More than 5 Gensets but less than 10 = 5 Marks			
	Less than 5 Gensets = Not Qualified for Evaluation			
7	Cumulative last 5 years revenue/turnover of the company.(2019-2024).		15	15
	(Attach document Proof as Annex "J")			
	Greater than Rs. 300 million = 15 Marks			
	Greater than Rs. 200 million but less than 300 million = 10 Marks			
8	Greater than Rs. 100 million but less than 200 million = 05 Marks		15	15
	Less than 100 million = Not Qualified for Evaluation			
	Obtained Marks	0	70	60
	Remarks	Not Qualified	Qualified	Qualified




 2/6
 03/12/24