

# SUMMARY OF BID EVALUATION REPORT

I.R.O

NCB-S-06/2024

OPENED ON 16-12-2024 AT 12:30 HOURS  
(As Per Rule-35 of PPRA Rules, 2004)

1. Name of Procuring Agency: SUKKUR ELECTRIC POWER COMPANY (SEPCO)
2. Method of Procurement: Single Stage One Envelope Procedure (NCB)
3. Title of Procurement: FOR PROCUREMENT OF 110V, DC, BATTERY CHARGER
4. Tender Inquiry No.: NCB-S-06/2024 (Lot-I)
5. PPRA Ref. No. (TSE) TS550560E
6. Date & Time of Opening of Bid: 16-12-2024 at 12:30 Hours
7. No of Bids Received: Two (02)
8. Criteria for Bid Evaluation: Single Stage One Envelope Procedure (NCB)
9. Details of Bid(s)Evaluation: As under:

Name of Bidder	Marks (Lot-I)		Item Description	Evaluated Cost (PKR)	Rule/Regulation/SBD*/Policy/ Basis for Rejection/Acceptance as per Rule-35 of PPRA Rules-2004.
	Technical	Commercial			
M/s Electroways Lahore	Responsive	Responsive	110V, DC, Battery Charger	302,300x12= 3,627,600/-	Accepted
M/s Pakwel Equipment Lahore	Responsive	Responsive	110V, DC, Battery Charger	357,500x12= 4,290,000/-	Most Advantageous Bidder Keeping in view the "No Load Losses & A.C Component in D.C Output (Ripples) offered by M/s Pakwel Equipment are less than the losses offered by M/s Electroways.

## REMARKS:

10. On the basis of detailed evaluation of bids M/s Pakwel Equipment Lahore has been declared as substantially Qualified Responsive Most Advantageous Bidder.

No. CE (DEV.)/PMU/SEPCO/SUK/NCB-S-06/2024/ 4246-49 Dated: 09-01-2025

- 1) Forward to Deputy Director-III, Public Procurement Regulatory Authority, Cabinet Division, 1<sup>st</sup> Floor, FBC Building, Sector G-5/2 Islamabad **for uploading on PPRA Website.**
- 2) Manager (MIS) SEPCO Sukkur **for uploading on SEPCO Website.**
- 3) M/s Electroways, 17-A, Fateh Sher Road, New Mozang Lahore.
- 4) M/s Pakwel Equipment, 76-Fazal Park # 1, Street # 1, Opposite Ali Hajveri Mosque, Shad Bagh Lahore.

  
CHIEF ENGINEER (DEV.),  
PMU, SEPCO, SUKKUR.