(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN

Method of Procurement: Single Stage Two Envelope

3. Title of Procurement: For the procurement of 11KV Capacitor Unit 200KVAR

4. Tender Inquiry No.: <u>Tender No.13/2024-25</u>

PPRA Ref. No.(TSE): <u>TS545486E</u>.

6. Date & Time of Bid Closing: 10.09.2024 at 11:45

7. Date & Time of Bid Opening: 10.09.2024 at 12:15

8. No of Bids Received: Three (03)

9. Criteria for Bid Evaluation: As per bidding document

10. Details of Bid (s)Evaluation: As under:-

Name of Bidder	Technical Marks (if applicable)	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as Per Rule 35 of PP Rules, 2004.
M/s Siddique Sons Engineering (Pvt) Ltd Lahore.	Responsive	
M/s Trace Engineering & Consultant (Pvt) Ltd Lahore.	Non- Responsive	 Due to Following reasons:- Not attached the satisfactory operation certificate of offered capacitor having type BAM12/√3-200-1W for a continuous period of at least three years prior to deadline for submission of bids. As per purchase orders attached with the bid, Bidder /Manufacturer has not supplied 70% quantity of tendered material (with External fuse as per clause 1.1 of NTDC Specifications (P-78:2010) for similar or higher rating during the last five years. The offered Capacitor Unit (BAM 12/√3-200-1-W) is non type tested.
M/s FICO HI-Tech (Pvt) Ltd Gujranwala	Non- Responsive	 Due to the following reasons:- Five Year supply record not attached. Purchase order, delivery challan and inspection report of already supplied tendered material not attached with bid. Bidder has not attached letter of technical bid, bid security and other relevant documents with Technical Bid. No Performance certificate attached of offered tendered material with bid for a continuous period of at least three years prior to deadline for submission of bids. On the Basis of above missing documents, the bid is incomplete.

Addl. Chief Engineer (Proc.)
PMU MEPCO Multan.